



## FIRE PREVENTION WING - FIRE NO OBJECTION CERTIFICATE

File. No: 2021-TRF-117509

Name and Address of the Premises:	St.Joseph's English Medium High School, D.No.45-1-20, Gunadala, Vijayawada.
Name of the Owner / Occupier:	Sr. Nirmala Nemalikanti

## Details of Building:

Plot Area (in Sq. Meters)	6209.15 Sq.Meters
No. of Blocks	TWO
Height of the Building from abutting road level to terrace (in meters)	11.85 Meters

## Floor Wise Occupancy details

Sl. No.	Floor	Built up area (in Sq.Meters)		Type of Occupancy	
		Block 1	Block 2	Block 1	Block 2
1.	Ground Floor	553.83	241.85	Educational	Educational
2.	First Floor	553.83	241.85	Educational	Educational
3.	Second Floor	553.83	241.85	Educational	Educational

## Open spaces in Meters (Block-1)

Front	03.00	Back	01.00	Side - 1	00.00	Side - 2	00.00
-------	-------	------	-------	----------	-------	----------	-------

## Open spaces in Meters (Block-2)

Front	03.00	Back	00.00	Side - 1	06.00	Side - 2	03.05
-------	-------	------	-------	----------	-------	----------	-------

## Means of Escape (Staircase)

Sl. No.	Details of Staircases	Provided			
		Block A	Block B	Block A	Block B
1.	No of Staircases	01 No	01 No	01.20 Mtrs	01.20 Mtrs

## Fire Fighting Equipment as show in the Annexure

Renewal of No Objection Certificate is hereby Issued along with Annexure Under Section 13 of Andhra Pradesh Fire Service Act, 1999 and under Rule 15 of Andhra Pradesh Fire and Emergency Operations and Levy of Fee Rules 2006 to the above Premises within the Jurisdictions of Vijayawada Municipal Corporation subject to the Maintenance of Fire Fighting Equipment in Good Working and other conditions and details Mentioned in the Annexure.

No Objection Certificate is valid up to 11/11/2024 or till it has been duly cancelled (Whichever is earlier)

Commissioner,  
Vijayawada Municipal Corporation.

Signed by V Prasanna  
Venkatesh I A S  
Date: 17-01-2022 21:21:46  
Reason: Approved

*St. Nirmala*  
PRINCIPAL

St. Joseph's English Medium High School  
GUNADALA, VIJAYAWADA-520004.

*F. B. Anand Reddy*  
CORRESPONDENT

St. Joseph's English Medium High School  
GUNADALA, VIJAYAWADA-520004.

**VIJAYAWADA MUNICIPAL CORPORATION**  
**FIRE PREVENTION WING**  
**ANNEXURE TO FIRE NO OBJECTION CERTIFICATE**  
**Rc.No.2021-TRF-117509 Dated: 06-12-2021.**

**Sub:** Vijayawada Municipal Corporation – Fire Prevention Wing - Issuance of Annexure to Renewal of No Objection Certificate for Occupancy to the Existing Education Building of St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada, Krishna District - Regarding.

- Ref:** 1.N.O.C.for Occupancy Rc.No.236/FPW/VMC/2013 Dt: 12-11-2013 of the Commissioner, Vijayawada Municipal Corporation.  
2.Ack.No.2021-TRF-117509 Dt: 14-10-2021 of the St. Joseph's English Medium High School, D.N.o.45-1- 20, Gunadala, Vijayawada, Krishna District.  
3.Inspection Report Rc.No.2021-TRF-117509, Dt: 29-11-2021 of the Officials of Fire Prevention Wing, Vijayawada Municipal Corporation.  
4. G.O.Ms.No.154, M.A & U.D Dept. Dt.13-03-2007.  
5. G.O.Ms.No.174, M.A & U.D Dept. Dt. 24-02-2009.  
6. Rc.No.1428/E2/2006 Dt.10-02-2014 of DGFS,AP,Vijayawada.  
7. G.O.M.s.No.169,HOME(PRISONS&FIRE)Dept,Dt:19-12-2019.  
8. G.O.M.s.No.90,HOME(PRISONS&FIRE)Dept,Dt:13-08-2021.  
9. G.O.M.s.No.120,HOME(PRISONS&FIRE)Dept,Dt:25-10-2021.

\*\*\*\*\*

Vide reference 1<sup>st</sup> cited, No Objection Certificate for Occupancy was issued to Educational Building St. Joseph's English Medium High School, D.NO.45-1-20, Gunadala, Vijayawada, Krishna District.

Vide reference 2<sup>nd</sup> cited, Sri. Sr. Nirmala Nemalikanti, Head Mistress of St. Joseph's English Medium High School has requested for issue of Renewal of Fire No Objection Certificate for Occupancy to the Education Building of St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada, Krishna District.

Vide reference 3<sup>rd</sup> cited the Officials of Fire Prevention Wing have inspected the building on 29-11-2021 and recommended for the issuance of Renewal of No Objection Certificate for Occupancy for the above Education Building.

**PART – A: GENERAL INFORMATION**

1	Name and Address of the Building with Land Marks	St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada, Krishna District.			
2	Name and Address of Builder/ a)Developer/Owner b)Occupier/Tenant and Telephone No.s	Sri. Sr.Nirmala Nemalikanti, Head Mistress St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada , Krishna District.			
3	Details of the Management/ Representative present at the time of Inspection	Sl. No.	Name	Designation/ Working as	Contact No.
		1.	Sr. Nirmala Nemalikanti	Head Mistress	0866-2451078
4.	Plot Area(in Sq. Meters)	6209.15 Sq.Meters			
5.	No. of Blocks	Two			
6.	Height of the Building from abutting road level to terrace(in meters)	11.85 Meters			

(Contd...P2)

*Sr. Nirmala*  
**PRINCIPAL**  
**St. Joseph's English Medium High School**  
**GUNADALA, VIJAYAWADA-520004.**

*F. D. Chandra*  
**CORRESPONDENT**  
**St. Joseph's English Medium High School**  
**GUNADALA, VIJAYAWADA-520004**

**PART – B: BUILDING INFORMATION****1. a). Open spaces: Block - 1**

Side	Open Space Required as per G.O.168	Open space available	Rectification of Deficit	Action taken	Deficit
West(Front)	03.00 Meters	03.00 Meters	Nil	Nil	NIL
North	06.00 Meters	NIL	Provision of Yard Hydrant as a remedial Measure	Yard Hydrant Provided as a remedial Measure	06.00 Meters
South	06.00 Meters	NIL			06.00 Meters
East	06.00 Meters	01.00 Meters			05.00 Meters

**1. a). Open spaces: Block - 2**

Side	Open Space Required as per G.O.168	Open space available	Rectification of Deficit	Action taken	Deficit
East (Front)	03.00 Meters	03.00 Meters	Nil	Nil	NIL
North	06.00 Meters	06.00 Meters	NIL	NIL	NIL
West	06.00 Meters	NIL	Provision of Yard Hydrant as a remedial Measure	Yard Hydrant Provided as a remedial Measure	06.00 Meters
South	06.00 Meters	03.05 Meters			02.95 eters

**b). Floor Wise Occupancy details:**

Sl. No.	Floor	Built up area (in Sq.Meters)		Type of Occupancy	Occupant Load	
		Block-A	Block- B		Block-A	Block- B
1.	Ground Floor	553.83	241.85	Educational	138	60
2.	First Floor	553.83	241.85	Educational	138	60
3.	Second Floor	553.83	241.85	Educational	138	60

**1. Means of Escape (Staircase):**

S.No	Floor wise Details	Occupant Load as per NBC-2016		MOE Required as per NBC-2016		MOE Provided		Deficit
		Block A	Block B	Block A	Block B	Block A	Block B	
1	Ground Floor	138	60	$138 \times 0.65 = 89.7\text{cm}$ (.89 Mtrs Doors)	$60 \times 0.65 = 39\text{cm}$ (0.39Mtrs)Doors	Sufficient Doors were Provided		Nil
2	First Floor	138	60	$138 \times 0.1 = 13.8\text{m}$ (01.38 Mtrs) staircase	$60 \times 0.1 = 6\text{cm}$ (0.60Mtrs)staircase	02.40 Mtrs Staircase	02.40 Mtrs Staircase	Nil
3	Second Floor	138	60	$138 \times 0.1 = 13.8\text{cm}$ (01.38 Mtrs) staircase	$60 \times 0.1 = 6\text{cm}$ (0.60Mtrs)staircase	02.40 Mtrs Staircase	02.40 Mtrs Staircase	Nil

**Details of Fire Precautionary Fees remitted:**

Sl.No.	DD. No.	Date	Amount	Place
1.	010750	30-11-2021	36,000/-	South India Bank

(Contd...P3)

**PART – C: FIRE PROTECTION AND FIRE PRECAUTIONARY MEASURES:**

**Minimum Fire Fighting Installations required as per Table-23, Part-IV of NBC-2005.**

	SI No	Fire Fighting Installations	Required		Provided		Deficit
			Block-A	Block- B	Block-A	Block- B	
Part A	i	Fire Extinguishers	24 No.s		24 No.s		NIL
	ii	Hose Reel	6 No.s		6 No.s		NIL
	iii	Terrace Tank.of water capacity	20,000 Ltrs		20,000 Ltrs		NIL
	iv	Fire Pump 450LPM	2 No.s		2 No.s		NIL
Part B (Additional Fire Safety)	v	Yard Hydrant	3 No.s		3 No.s		NIL
	vi	Two way Fire Brigade inlet	2 No.s		2 No.s		NIL
	vii	Fire Buckets with stands	6 Sets		6 Sets		NIL
	viii	Manually operated electric Fire Alarm System	6 No.s		6 No.s		NIL

The Existing Education Building St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada, Krishna District is provided with required fire safety measures.

The Fire Safety systems were tested by the committee members during the inspection and Performance found satisfactory. Therefore, this Office has issued Annexure to Renewal of No Objection Certificate for Occupancy to St. Joseph's English Medium High School, D.N.o.45-1-20, Gunadala, Vijayawada, Krishna District. Subject to the following conditions.

i	All the Fire protection arrangements shall be maintained in good working condition as seen during inspection.
ii	The escape/ exit routes shall not be kept locked/ blocked or encroached.
iii	All the occupants must know the correct method of operation of the fire fighting system.
iv	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All Staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition/ alteration if any in the building shall be carried only with the prior permission from this Department.
vii	Mock drills should be conducted for every 3 months.
viii	The management has to submit annual fire audit report by checking all fire systems satisfactory working condition in premises.
ix	Fire extinguishers to be certified every year from licensed authority.
x	Emergency Contact Number of Nearest Fire Station to be displayed.

This Renewal of No Objection Certificate for Occupancy is valid up to 11-11-2024(For a period of three years only) as per G.O.M.s.No.169,HOME(PRISONS&FIRE) Dept, Dt:19-12-2019.The Owner / Occupant shall submit application for its renewal duly remitting the prescribed fees, as per G.O.Ms.No. 71, Home (Prisons – A) Dept. Dt. 01-04-2010, two months before the date of renewal.

The Annexure to Renewal of No Objection Certificate for Occupancy is with regard to fire safety only and this is not valid for other claims.

*Sr. Nandee*

PRINCIPAL

*F. B. Chand Reddy*

CORRESPONDENT

*[Signature]*  
Regional Fire Officer,  
Fire Prevention Wing,  
Vijayawada Municipal corporation.

St. Joseph's English Medium High School  
GUNADALA, VIJAYAWADA-520004.

*[Signature]*  
6/12/24  
DF

*[Signature]*  
Sfo.  
6/12/24